# CERTIFICATE OF CONFORMITY

**Certificate No.:** LC22343-1 Date Issued: October 23, 2024

Project No.: **Certification System: Type 3** T-22343

(ISO/IEC 17067)

Client No.: LC1231751

Applicant: Victron Energy B.V

De Paal 35 1351 JG Almere

The Netherlands

Issued by:

**Certification Manager** 

#### **Products:**

- Battery Charger
- Model Nos.:
  - Blue Smart IP65 Charger 12/25(1) 120V NEMA 1-15
  - Blue Smart IP65 Charger 24/13(1) 120V NEMA 1-15
- Ratina:
- Blue Smart IP65 Charger 12/25(1) 120V NEMA 1-15
  - (12/25) Input: Nominal Voltage 110-120VAC 50/60Hz, 5A, 380W
  - (12/25) Input: Voltage range 100-130VAC 45-65Hz
  - (12/25) Output: 12VDC, 25A
- Blue Smart IP65 Charger 24/13(1) 120V NEMA 1-15
  - (24/13) Input: Nominal Voltage 110-120VAC 50/60Hz, 5A, 395W
  - (24/13) Input: Voltage range 100-130VAC 45-65Hz
  - (24/13) Output: 24VDC, 13A

## Applicable requirements:

- UL 1236 (Edition 8)
- CSA C22.2 No.107.2-01 (R2016)

### **Conditions of acceptability:**

None

#### **General Note:**

Refer to LC Listing Report no. 10.03.22343-1 Rev.0

Page 1 of 1

The 'C' and 'US' indicators adjacent to the LabTest Certification Mark shall signify that the product has been evaluated by an accredited laboratory to the applicable Canadian and US Standards. The subject area shall be displayed with the LabTest Certification Mark to identify the Standard Number, and Revision Level.